



- NOTES:**
1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR CONSTRUCTING ADEQUATE BALLAST TO OFFSET FLOTATION FORCES ACTING ON MANHOLES.
 2. ALL REINFORCEMENT IS SUBJECT TO ENGINEER'S APPROVAL BEFORE CONSTRUCTION.
 3. ALL MANHOLES SHALL CONFORM TO ASTM SPEC C478.

**TOWNSHIP OF FLORENCE
WATER & SEWER DEPARTMENT**

**SANITARY SEWER
PRECAST CONCRETE
4'-0" DIA. MANHOLE DETAIL**

DATE :	6/05
DWN BY :	
REVISIONS	
BY DATE	